



**The City of Eagle Pass  
Fire Marshal's Office  
2558 El Indio Hwy  
Eagle Pass, Texas 78852  
Phone (830)773-1915  
Fax (830)757-9152  
[ecuevas@eaglepasstx.us](mailto:ecuevas@eaglepasstx.us)**

### **Flammable/Combustible Liquid Tank Plan Submittal Requirements**

Flammable/Combustible liquid tanks, installed in the City of Eagle Pass shall meet all the requirements of the 2018 International Fire Code, local amendments, as well as all applicable NFPA standards. All final systems testing, and inspections will be witnessed by the Eagle Pass Fire Marshal's Office. The following is a check list of information that should be used as an aid and is not intended to cover every code requirement.

#### **Permit Application**

**Copy of License current issued by The State of Texas Fire Marshal**

System designer

Contractor/Company

Installers

#### **Submittal Packet**

System Design Description

Manufacturer's Product Information Sheets of Listed Devices

Specifications for piping

List of materials

#### **Scaled Plans (1/8" minimum scale) 1 PDF copy**

Legend

North Arrow

Site plan with accurate dimensions

Distances from property lines and all adjacent structures on and off site

Location of emergency shut off

Location of extinguisher

System designers stamp with wet signature

#### **Modification permit**

Permit application

Copy of licenses

Plans 1/8" scale, 2 copies, stamped and wet signed

Legend showing existing, relocated or additional equipment

cut sheets for each new device or piece of equipment

#### **Required inspections**

Emergency shut off

Low pressure hydro

Underground visual

**Tank Removal**

Copy of license

Scope of work

Inspector onsite during pull

Plan review process may take up to 10 working days. Incomplete plans may require that the plans be resubmitted. System acceptance inspections are required and should be called in at least 24 hours prior to requested inspection times. A re-inspection fee of \$15 will be assessed on systems that are not in complete compliance with all applicable codes. All devices will be tested in an approved manner. Installation/modification permit and an approved set of plans shall remain at the job site and provided to inspectors when requested.