



The City of Eagle Pass Fire Marshal's Office

2558 El Indio Hwy
Eagle Pass, Texas 78852
Phone: (830)773-1915
Fax: (830)757-9152
ecuevas@eaglepasstx.us



Commercial kitchen fire suppression systems plan submittal requirements

Fixed pipe suppression systems installed in the City of Eagle Pass shall meet the requirements of the 2018 International Fire Code, local amendments, as well as all applicable NFPA Standards. All final system testing, and inspections will be witnessed by the City of Eagle Pass Fire Marshal's Office. The following is a check list of information that should be used as an aid and is not intended to cover every code requirement.

Permit Application

Copy of License current issued by The State of Texas Fire Marshal (1 copy)

System designer

Contractor/Company

Installers

Submittal Packet (1copy)

System Design Description

Manufacturer's Product Information Sheets of Listed Devices

Flow rates of nozzles

Specifications for piping

List of Materials

Addressable device list/zone

(1) 1/8" Scaled Plan (1) PDF copy

Legend

North Arrow

Plans shall reflect the entire building/suite as well as the area of operation

All rooms labeled for intended use

Arrangement of appliances

Layout of piping

Nozzle arrangement

Location of pull station

Gas shut off and/or shunt trip

All exits and means of egress

System designers stamp with wet signature

Required inspections

Pull station

Air test

Fusible link

Gas shut off

Electric shunt trip

Alarm system activation

Plan review process may take up to 10 working days. Incomplete plans may require that the plans be resubmitted. System acceptance inspections are required and should be called in at least 24 hours prior to requested inspection times. A re-inspection fee of \$15 will be assessed on systems that are not in complete compliance with all applicable codes. All devices will be tested in an approved manner. Installation/modification permit and an approved set of plans shall remain at the job site and provided to inspectors when requested.