



The City of Eagle Pass Fire Marshal's Office

3295 Bob Rogers Drive
Eagle Pass, Texas 78852
Phone: (830)773-7781
Fax: (830)773-7803
rocardona@eaglepasstx.us

Commercial kitchen fire suppression systems plan submittal requirements

Fixed pipe suppression systems installed in the City of Eagle Pass shall meet the requirements of the 2009 International Fire Code, local amendments, as well as all applicable NFPA Standards. All final system testing and inspections will be witnessed by the City of Eagle Pass Fire Marshal's Office. The following is a check list of information that should be used as an aid and is not intended to cover every code requirement.

Permit Application

Copy of License current issued by The State of Texas Fire Marshal (1 copy)

System designer
Contractor/Company
Installers

Submittal Packet (1copy)

System Design Description
Manufacturer's Product Information Sheets of Listed Devices
Flow rates of nozzles
Specifications for piping
List of Materials
Addressable device list/zone

1/8" Scaled Plans (2 copies)

Legend
North Arrow
Plans shall reflect the entire building/suite as well as the area of operation
All rooms labeled for intended use
Arrangement of appliances
Layout of piping
Nozzle arrangement
Location of pull station
Gas shut off and/or shunt trip
All exits and means of egress
System designers stamp with wet signature

Required inspections

Pull station

Air test

Fusible link

Gas shut off

Electric shunt trip

Alarm system activation

Plan review process may take up to 10 working days. Incomplete plans may require that the plans be resubmitted. System acceptance inspections are required and should be called in at least 24 hours prior to requested inspection times. A re-inspection fee of \$15 will be assessed on systems that are not in complete compliance with all applicable codes. All devices will be tested in an approved manner. Installation/modification permit and an approved set of plans shall remain at the job site and provided to inspectors when requested.