



The City of Eagle Pass Fire Marshal's Office

3295 Bob Rogers Drive
Eagle Pass, Texas 78852
Phone: (830)773-7781
Fax: (830)773-7803
rocardona@eaglepasstx.us

Fire Alarm Plan Submittal Requirements

Fire alarm systems installed in the City of Eagle Pass shall meet the requirements of the 2009 International Fire Code, local amendments, as well as all applicable NFPA Standards. All final system testing and inspections will be witnessed by the City of Eagle Pass Fire Marshal's Office. The following is a check list of information that should be used as an aid and is not intended to cover every code requirement.

Permit Application

Copy of License current issued by The State of Texas Fire Marshal (1 copy)

System designer
Contractor/Company
Installers

Submittal Packet (1copy)

System Design Description
Manufacturer's Product Information Sheets of Listed Devices
Battery Calculations
Voltage Drop Calculations
Wiring Specifications
Riser Diagram
List of materials
Addressable Device List/Zone Legend
List Primary and Secondary Power

No less than 1/8" Scaled Plans (1 copy to be signed and returned 2nd copy may be pdf format)

Legend
North Arrow
Floor Plans Drawn that is free of extraneous information
All rooms labeled for intended use
Separate circuit wiring (not conduit) diagrams for initiating and indicating Circuits
Completed device to device wiring including end of line resistors where Applicable
Device address numbers
System designers stamp with wet signature

Modification permit (up to 10 devices)

Permit application
Copy of licenses
Plans no less than 1/8" scale, 2 copies, stamped and wet signed
Legend showing existing, relocated or additional devices
Cut sheets for each new device or piece of equipment

Required inspections

Pull station

Audio visual devices

Visual devices

Monitoring capabilities

Other systems tied to system

Plan review process may take up to 10 working days. Incomplete plans may require that the plans be resubmitted. System acceptance inspections are required and should be called in at least 24 hours prior to requested inspection times. A re-inspection fee of \$15 will be assessed on systems that are not in complete compliance with all applicable codes. All devices will be tested in an approved manner. Installation/modification permit and an approved set of plans shall remain at the job site and provided to inspectors when requested.