



The City of Eagle Pass Fire Marshal's Office

3295 Bob Rogers Drive
Eagle Pass, Texas 78852
Phone (830)773-7781
Fax (830)773-7803
rocardona@eaglepasstx.us

Fire Sprinkler Plan Submittal Requirements

Fire sprinkler systems installed in the City of Eagle Pass shall meet the requirements of the 2009 International Fire Code, local amendments, as well as all applicable NFPA Standards. All final system testing and inspections will be witnessed by the City of Eagle Pass Fire Marshal's Office. The following is a check list of information that should be used as an aid and is not intended to cover every code requirement.

Permit Application

Copy of License current issued by The State of Texas Fire Marshal (1 copy)

System designer
Contractor/Company
Installers

Submittal Packet

System Design Description
Building information to include hazard type and construction type
Manufacturer's product information sheets of listed devices and equipment
Hydraulic calculations
Friction loss calculations
Piping and fittings specifications
Riser diagram and specifications
List of materials

Scaled Plans (no less than 1/8" scale)

Site plan with hydrant locations and distance and main sizes
North Arrow
Legend with appropriate sprinkler head specification
Floor plans drawn that are free extraneous information
All rooms labeled for intended use to include dimensions
Hanger details
Full height cross section of each floor
Location of partitions and fire walls
Total number of heads for each riser per floor
Location of risers
Locations of all piping sizes
Location of 2 1/2" Siamese FDC
Location of alarm bell
Capacity dry pipe or anti-freeze systems
All labeling and signage posted in accordance with NFPA 13, 13D, 13R
System designer stamp with wet signature

Modification permit

Permit application

Copy of licenses

Plans, no less than 1/8" scale

Legend showing existing, relocated additional or plugged heads or lines devices

Cut sheets for each new device or piece of equipment

Indicate hazard type for area served

Plan review process may take up to 10 working days. Incomplete plans may require that the plans be resubmitted. System acceptance inspections are required and should be called in at least 24 hours prior to requested inspection times. A re-inspection fee of \$15 will be assessed on systems that are not in complete compliance with all applicable codes. All devices will be tested in an approved manner. Installation/modification permit and an approved set of plans shall remain at the job site and provided to inspectors when requested.